

# Emission Test Certificate

Monday 25<sup>th</sup> March 2019

Supplier: FloorTex (8 Whiteside Road, Clayton South, VIC, 3169, Australia)

Sample Description: Penguin Hybrid Flooring

Date Tested: February 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours):

<p><b>Green Building Council of Australia</b> Green Star Design &amp; As Built v1.1 - 13.1.2B &amp; 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p><b>Penguin Hybrid Flooring</b></p>
<p>Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.020 mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde Emission Rate Limit: ≤0.1 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: 0.013 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

CV190272